



Microbac Laboratories, Inc., Newton

CERTIFICATE OF ANALYSIS

1HI0527

Osage County R-1 School District

Project Name: Mo Schools Lead Testing

Lyle Best  
614 S. Poplar  
Chamois, MO 65024

Project / PO Number: N/A  
Received: 09/09/2024  
Reported: 09/18/2024

Analytical Testing Parameters

Client Sample ID:	01-008 SW Sink	Collected By:	EB
Sample Matrix:	Drinking Water	Collection Date:	08/13/2024 9:05
Lab Sample ID:	1HI0527-01		

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		09/10/24 1553	09/11/24 1653	RVV

Client Sample ID:	01-009 NE Sink	Collected By:	EB
Sample Matrix:	Drinking Water	Collection Date:	08/13/2024 9:09
Lab Sample ID:	1HI0527-02		

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	<0.4	0.4	ppb	2		09/10/24 1553	09/11/24 1659	RVV

Client Sample ID:	01-010 SE Sink	Collected By:	EB
Sample Matrix:	Drinking Water	Collection Date:	08/13/2024 9:11
Lab Sample ID:	1HI0527-03		

Determination of Total Metals	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
200.8								
Lead, total	0.4	0.4	ppb	2		09/10/24 1553	09/11/24 1714	RVV

Definitions


RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Sue Thompson  
Client Services Manager  
09/18/24 07:18



Osage County R-1 School District  
 P#: Carolyn Jackson

**SITE INFORMATION**

**Sampler:**  
 Project: Mo Schools Lead Testing  
 PWSID# Mo Schools Lead Testing

**REPORT TO:**  
 Lyle Best  
 Osage County R-1 School District  
 614 S. Poplar  
 Chamois, MO 65024

**Lyle Best**  
 Osage County R-1 School District  
 614 S. Poplar  
 Chamois, MO 65024

**SPECIAL INSTRUCTIONS**

None  
**Turn Around Time**  
 Standard  RUSH, need by \_\_\_/\_\_\_/\_\_\_

**LAB USE ONLY**

Work Order: **2410527**  
 Temperature: **20.6**  
 Turn-Cooler:

Custody Seal  
 Containers Intact  
 COC/Labels Agree  
 Preservation Confirmed  
 Received on-time

Number	Sample Identification / Client ID	Matrix	Sample Type	Date	Time	Number of Containers	Analyses	Lab Sample Number
01-008	SW Sink	Drink Wtr	GRAB	8/13/24	9:05 AM	1	pb-t-200.8	1
01-009	NE Sink	Drink Wtr	GRAB	8/13/24	9:05 AM	1	pb-t-200.8	2
01-010	SE Sink	Drink Wtr	GRAB	8/13/24	9:11 AM	1	pb-t-200.8	3

Relinquished By \_\_\_\_\_ Date/Time \_\_\_\_\_

Relinquished By *Carlin Jackson* Date/Time *9/10/24 8:27*

Received By \_\_\_\_\_ Date/Time \_\_\_\_\_

Received for Lab By *Carlin Jackson* Date/Time *9/10/24 8:27*

Original - Lab Copy Yellow - Sampler Copy

Remarks:

- RT Routine
- SP Special
- NC New Line Ext (ONLY)
- RL Replacement
- Valid Bacteria Sample Types
- RP-UP Repeat Up
- RP-DN Repeat Down
- RP-OR Repeat Original
- RP-OT Repeat Other